



Internet: [www.awqc.com.au](http://www.awqc.com.au)

Email: [producttesting@awqc.com.au](mailto:producttesting@awqc.com.au)

## FINAL REPORT

Report ID : 339139

### Report Information

**Submitting Organisation :** 00109358 : Parchem Construction Supplies Pty Ltd  
**Account :** 130335 : Parchem Construction Supplies Pty Ltd  
**AWQC Reference :** 130335-2022-CSR-1 : Prod Test: Fosroc Nitoseal PU250  
**Project Reference :** PT-4873  
**Product Designation :** Fosroc Nitoseal PU250 - Polyurethane Joint Sealant.  
**Composition of Product :** Polyurethane Polymer.  
**Product Manufacturer :** Parchem Construction Supplies, Wyong, NSW, AUSTRALIA.  
**Use of Product :** In-Line/Polyurethane Joint Sealant.  
**Sample Selection:** As provided by the submitting organisation.  
**Testing Requested :** **AS/NZS 4020:2018 TESTING OF PRODUCTS FOR USE IN CONTACT WITH DRINKING WATER**  
**Product Type :** Composite  
**Samples :** Samples were prepared and controlled as described in Appendix A of AS/NZS 4020:2018  
**Extracts :** Extracts were prepared as described in Appendix/Clause C, D, E, F, G, H, 6.8.  
**Project Completion Date :** 30-May-2022  
**Project Comment :** Product sample received in the week 23-Feb-2022 and testing commenced 09-Mar-2021.

PLEASE NOTE THAT THIS REPORT SHALL NOT BE REPRODUCED EXCEPT IN FULL

THE RESULTS STATED IN THIS REPORT RELATE TO THE SAMPLE OF THE PRODUCT SUBMITTED FOR TESTING TO AS/NZS 4020:2018. ANY CHANGES IN THE MATERIAL FORMULATION, PROCESS OF MANUFACTURE, THE METHOD OF APPLICATION, OR THE SURFACE AREA-TO-VOLUME RATIO IN THE END USE, COULD AFFECT THE SUITABILITY OF THE PRODUCT FOR USE IN CONTACT WITH DRINKING WATER



Corporate Accreditation No.1115  
Chemical and Biological Testing  
Accredited for compliance  
with ISO/IEC 17025 - Testing



#### Notes

1. Uncertainty of Measurement is reported with a coverage factor of 2 providing approximately 95% confidence interval
2. Where a result is required to meet compliance limits the associated measurement uncertainty must be considered. Measurement uncertainty is available at <https://www.awqc.com.au/our-services/Water-quality-testing-and-analysis/measurement-uncertainty>

**FINAL REPORT**

Report ID : 339139

**Summary of Results**

APPENDIX/CLAUSE	RESULTS
C – Taste	Passed at an exposure of 2500 mm <sup>2</sup> per Litre.
D – Appearance	Passed at an exposure of 2500 mm <sup>2</sup> per Litre.
E – Growth of Aquatic Micro-organisms	Passed at an exposure of 2500 mm <sup>2</sup> per Litre.
F – Cytotoxic Activity	Passed at an exposure of 2500 mm <sup>2</sup> per Litre.
G – Mutagenic Activity	Passed at an exposure of 2500 mm <sup>2</sup> per Litre.
H – Metals	Passed at an exposure of 2500 mm <sup>2</sup> per Litre.
6.8 – Organic Compounds	Passed at an exposure of 2500 mm <sup>2</sup> per Litre.

**Test Methods**

Test(s) in Appendix	AWQC Test Method	NATA Accredited
C	T0320-01	Y
D	TO029-01 & TO018-01	Y
E	TO014-03	Y
F	TM-001	Y
G	TM-002	Y
H	TIC-006	Y

**Organic Test Methods**

Test(s) in Clause	Test Method	NATA Accredited
Clause 6.8	TMZ-M36	Y
	EP239	Y
	EP132-LL	Y
	EP075C	Y
	EP075ASIM	Y



Corporate Accreditation No. 1115  
Chemical and Biological Testing  
Accredited for compliance  
with ISO/IEC 17025 - Testing



Notes

1. Uncertainty of Measurement is reported with a coverage factor of 2 providing approximately 95% confidence interval
2. Where a result is required to meet compliance limits the associated measurement uncertainty must be considered. Measurement uncertainty is available at <https://www.awqc.com.au/our-services/Water-quality-testing-and-analysis/measurement-uncertainty/>



Internet: [www.awqc.com.au](http://www.awqc.com.au)

Email: [producttesting@awqc.com.au](mailto:producttesting@awqc.com.au)

## FINAL REPORT

Report ID : 339139

### Laboratory Information

Laboratory	NATA accreditation ID
Product Testing	1115
Australian Laboratory Services Pty Ltd - New South Wales	825,992
Inorganic Chemistry - Physical	1115
Organic Chemistry	1115
Protozoology	1115
Inorganic Chemistry - Metals	1115
Inorganic Chemistry - Waste Water	1115

Summary Comment : Not applicable.



Corporate Accreditation No.1115  
Chemical and Biological Testing  
Accredited for compliance  
with ISO/IEC 17025 - Testing



#### Notes

1. Uncertainty of Measurement is reported with a coverage factor of 2 providing approximately 95% confidence interval
2. Where a result is required to meet compliance limits the associated measurement uncertainty must be considered. Measurement uncertainty is available at <https://www.awqc.com.au/our-services/Water-quality-testing-and-analysis/measurement-uncertainty>



Internet: [www.awqc.com.au](http://www.awqc.com.au)

Email: [producttesting@awqc.com.au](mailto:producttesting@awqc.com.au)

## FINAL REPORT

Report ID : 339139

### CLAUSE 6.2 Taste

<b>Sample Description</b>	The sealant was applied onto a single sided glass substrate (25mm x 100mm) providing a total surface area of approximately 2500 mm <sup>2</sup> per Litre. Extracts were prepared using 1000 mL volumes of 50 mg/L hardness water.
<b>Extraction Temperature</b>	20°C ± 2°C.
<b>Test Method</b>	Taste (Appendix C)
<b>Test Information</b>	
<b>Scaling Factor</b>	Not applied.
<b>Results</b>	Not detected (sample and controls).
<b>Evaluation</b>	The product passed the requirements of clause 6.2 when tested at an exposure of 2500 mm <sup>2</sup> per Litre.
<b>Number of Samples</b>	2.
<b>Test Comment</b>	Not applicable.

Michael Glasson  
APPROVED SIGNATORY



Corporate Accreditation No.1115  
Chemical and Biological Testing  
Accredited for compliance  
with ISO/IEC 17025 - Testing



#### Notes

1. Uncertainty of Measurement is reported with a coverage factor of 2 providing approximately 95% confidence interval
2. Where a result is required to meet compliance limits the associated measurement uncertainty must be considered. Measurement uncertainty is available at <https://www.awqc.com.au/our-services/Water-quality-testing-and-analysis/measurement-uncertainty>



Internet: [www.awqc.com.au](http://www.awqc.com.au)

Email: [producttesting@awqc.com.au](mailto:producttesting@awqc.com.au)

## FINAL REPORT

Report ID : 339139

### CLAUSE 6.3 Appearance

**Sample Description** The sealant was applied onto a single sided glass substrate (25mm x 100mm) providing a total surface area of approximately 2500 mm<sup>2</sup> per Litre. Extracts were prepared using 1000 mL volumes of 50 mg/L hardness water.

**Extraction Temperature** 20°C ± 2°C.

**Test Method** Appearance (Appendix D)

**Scaling Factor** Not applied.

### Results

	<u>Test (- Blank)</u>	<u>Maximum Allowed</u>	<u>Units</u>
Colour	<1	5	HU
Turbidity	<0.1	0.5	NTU

**Evaluation** The product passed the requirements of clause 6.3 when tested at an exposure of 2500 mm<sup>2</sup> per Litre.

**Number of Samples** 1.

**Test Comment** Not applicable.

Andrew Ford  
APPROVED SIGNATORY



Corporate Accreditation No.1115  
Chemical and Biological Testing  
Accredited for compliance  
with ISO/IEC 17025 - Testing



#### Notes

1. Uncertainty of Measurement is reported with a coverage factor of 2 providing approximately 95% confidence interval
2. Where a result is required to meet compliance limits the associated measurement uncertainty must be considered. Measurement uncertainty is available at <https://www.awqc.com.au/our-services/Water-quality-testing-and-analysis/measurement-uncertainty>



Internet: [www.awqc.com.au](http://www.awqc.com.au)

Email: [producttesting@awqc.com.au](mailto:producttesting@awqc.com.au)

## FINAL REPORT

Report ID : 339139

### CLAUSE 6.4 Growth of Aquatic Micro-organisms

**Sample Description** The sealant was applied onto a single sided glass substrate (25mm x 100mm) providing a total surface area of approximately 2500 mm<sup>2</sup> per Litre. Extracts were prepared using 1000 mL volumes of test water.

**Test Method** Growth of Aquatic Micro-organisms (Appendix E)

**Inoculum** The volume of the inoculum was 100 mL

**Scaling Factor** Not applied.

#### Results

Mean Dissolved Oxygen	Control	7.4 mg/L
Mean Dissolved Oxygen Difference	Positive Reference	5.9 mg/L
	Negative Reference	<0.1 mg/L
	Test	1.70 mg/L

**Evaluation** The product passed the requirements of clause 6.4 when tested at an exposure of 2500 mm<sup>2</sup> per Litre.

**Number of Samples** 1.

**Test Comment** Not applicable.

Thuy Diep  
APPROVED SIGNATORY



Corporate Accreditation No.1115  
Chemical and Biological Testing  
Accredited for compliance  
with ISO/IEC 17025 - Testing



#### Notes

1. Uncertainty of Measurement is reported with a coverage factor of 2 providing approximately 95% confidence interval
2. Where a result is required to meet compliance limits the associated measurement uncertainty must be considered. Measurement uncertainty is available at <https://www.awqc.com.au/our-services/Water-quality-testing-and-analysis/measurement-uncertainty>



Internet: [www.awqc.com.au](http://www.awqc.com.au)

Email: [producttesting@awqc.com.au](mailto:producttesting@awqc.com.au)

## FINAL REPORT

Report ID : 339139

### CLAUSE 6.5 Cytotoxic Activity

**Sample Description** The sealant was applied onto a single sided glass substrate (25mm x 100mm) providing a total surface area of approximately 2500 mm<sup>2</sup> per Litre. Extracts were prepared using 1000 mL volumes of 50 mg/L hardness water.

**Extraction Temperature** 20°C ± 2°C.

**Test Method** Cytotoxic Activity (Appendix F)

**Scaling Factor** Not applied.

#### Results

24 HR	Non-cytotoxic response, healthy cell morphology with <30% cell death
48 HR	Non-cytotoxic response, healthy cell morphology with <30% cell death
72 HR	Non-cytotoxic response, healthy cell morphology with <30% cell death

**Blank Control Results** Blank; non-cytotoxic response, healthy cell morphology with <30% cell death

**Positive Control Results** Positive control; Cytotoxic response, unhealthy cell morphology with >70% cell death

The test extracts and blank extracts were used to prepare nutrient growth medium and subsequently used to grow a cell line (ATCC Number CCL 81) in the analysis. In addition zinc sulphate (0.4 mmol) was used for the positive control in the analysis.

**Evaluation** The product passed the requirements of clause 6.5 when tested at an exposure of 2500 mm<sup>2</sup> per Litre.

**Number of Samples** 1.

**Test Comment** Not applicable.

Stella Fanok  
APPROVED SIGNATORY



Corporate Accreditation No.1115  
Chemical and Biological Testing  
Accredited for compliance  
with ISO/IEC 17025 - Testing



#### Notes

1. Uncertainty of Measurement is reported with a coverage factor of 2 providing approximately 95% confidence interval
2. Where a result is required to meet compliance limits the associated measurement uncertainty must be considered. Measurement uncertainty is available at <https://www.awqc.com.au/our-services/Water-quality-testing-and-analysis/measurement-uncertainty>

**FINAL REPORT**

Report ID : 339139

**CLAUSE 6.6 Mutagenic Activity**

**Sample Description** The sealant was applied onto a single sided glass substrate (25mm x 100mm) providing a total surface area of approximately 2500 mm<sup>2</sup> per Litre. Extracts were prepared using 1000 mL volumes of 50 mg/L hardness water.

**Extraction Temperature** 20°C ± 2°C.

**Test Method** Mutagenic Activity (Appendix G)

**Scaling Factor** Not applied.

**Results**

<u>Bacteria Strain</u>	<u>Number of Revertants per Plate</u>				
	S9	Blank	Sample Extract	Positive Controls	
<i>Salmonella typhimurium</i> TA98	-	34, 26, 34	26, 23, 25	1500, 1394, 1481	<u>NPD</u> (20µg)
Mean ± Standard deviation		31.3 ± 4.6	24.7 ± 1.5	1458.3 ± 56.5	
	+	30, 34, 25	29, 31, 29	3354, 3119, 3147	<u>2-AF</u> (20µg)
Mean ± Standard deviation		29.7 ± 4.5	29.7 ± 1.2	3206.7 ± 128.4	
<i>Salmonella typhimurium</i> TA102	-	169, 203, 209	173, 184, 217	1760, 1804, 1722	<u>Mitomycin C</u> (10µg)
Mean ± Standard deviation		193.7 ± 21.6	191.3 ± 22.9	1762.0 ± 41.0	
	+	208, 212, 242	221, 186, 220	1466, 1739, 1938	
Mean ± Standard deviation		220.7 ± 18.6	209.0 ± 19.9	1714.3 ± 237.0	

The differences in the mean number of revertants between the blank and test extracts do not exceed two standard deviations; accordingly, there is no evidence of a mutagenic response.

**Comments** S9 was used as the metabolic activator. NPD (4-nitro-o-phenylenediamine) and Mitomycin C are specific positive controls for strains TA98 - and TA102 (- and +) respectively, while 2-AF (2-aminofluorene) when used in conjunction with S9 is a positive control for TA98+.

**Evaluation** The product passed the requirements of clause 6.6 when tested at an exposure of 2500 mm<sup>2</sup> per Litre.

**Number of Samples** 1.

**Test Comment** Not applicable.

Michael Glasson  
APPROVED SIGNATORY



Corporate Accreditation No. 1115  
Chemical and Biological Testing  
Accredited for compliance  
with ISO/IEC 17025 - Testing



**Notes**

1. Uncertainty of Measurement is reported with a coverage factor of 2 providing approximately 95% confidence interval
2. Where a result is required to meet compliance limits the associated measurement uncertainty must be considered. Measurement uncertainty is available at <https://www.awqc.com.au/our-services/Water-quality-testing-and-analysis/measurement-uncertainty/>



**FINAL REPORT**

Report ID : 339139

**CLAUSE 6.7**

**Metals**

**Sample Description**

The sealant was applied onto a single sided glass substrate (25mm x 100mm) providing a total surface area of approximately 2500 mm<sup>2</sup> per Litre. Extracts were prepared using 1000 mL volumes of 50 mg/L hardness water.

**Extraction Temperature**

20°C ± 2°C.

**Test Method**

Metals (Appendix H)

**Scaling Factor**

Not applied.

**Method of Analysis**

Concentration of the metals described in Table 2 of the AS/NZS 4020:2018 are determined as follows:

Aluminium, Antimony, Arsenic, Barium, Boron, Cadmium, Chromium, Copper, Iron, Lead, Manganese, Mercury, Molybdenum, Nickel, Selenium and Silver by Inductively Coupled Plasma Mass Spectrometry.

Results	Limit of Reporting mg/L	Blank mg/L	Test 1 mg/L	Test 2 mg/L	Max Allowed mg/L
<b>Final Extract</b>					
Aluminium	0.001	0.028	0.005	0.005	0.2
Antimony	0.0005	<0.0005	<0.0005	<0.0005	0.003
Arsenic	0.0003	0.0003	<0.0003	<0.0003	0.01
Barium	0.0005	0.0278	<0.0005	<0.0005	0.7
Boron	0.020	<0.020	<0.020	<0.020	1.4
Cadmium	0.0001	<0.0001	<0.0001	<0.0001	0.002
Chromium	0.0001	0.0003	<0.0001	<0.0001	0.05
Copper	0.0001	0.0477	<0.0001	<0.0001	2.0
Iron	0.0005	0.0042	<0.0005	<0.0005	0.3
Lead	0.0001	0.0007	<0.0001	<0.0001	0.01
Manganese	0.0001	0.0008	<0.0001	<0.0001	0.1
Mercury	0.00003	<0.00003	<0.00003	<0.00003	0.001
Molybdenum	0.0001	0.0003	<0.0001	<0.0001	0.05
Nickel	0.0001	0.0012	<0.0001	<0.0001	0.02
Selenium	0.0001	<0.0001	<0.0001	<0.0001	0.01
Silver	0.00003	<0.00003	<0.00003	<0.00003	0.1

**Evaluation**

The product passed the requirements of clause 6.7 when tested at an exposure of 2500 mm<sup>2</sup> per Litre.

**Number of Samples**

1.

**Test Comment**

Not applicable.

Dzung Bui

APPROVED SIGNATORY



Corporate Accreditation No. 1115  
Chemical and Biological Testing  
Accredited for compliance  
with ISO/IEC 17025 - Testing



Notes

1. Uncertainty of Measurement is reported with a coverage factor of 2 providing approximately 95% confidence interval
2. Where a result is required to meet compliance limits the associated measurement uncertainty must be considered. Measurement uncertainty is available at <https://www.awqc.com.au/our-services/Water-quality-testing-and-analysis/measurement-uncertainty>



Internet: [www.awqc.com.au](http://www.awqc.com.au)

Email: [producttesting@awqc.com.au](mailto:producttesting@awqc.com.au)

## FINAL REPORT

Report ID : 339139

### CLAUSE 6.8 Organic Compounds

**Sample Description** The sealant was applied onto a single sided glass substrate (25mm x 100mm) providing a total surface area of approximately 2500 mm<sup>2</sup> per Litre. Extracts were prepared using 1000 mL volumes of 50 mg/L hardness water.

**Extraction Temperature** 20°C ± 2°C.

**Test Method** Organic Compounds (Clause 6.8). The maximum allowed (Max Allowed) values are taken from the Australian Drinking Water Guidelines and Drinking-water Standards for New Zealand. Please note, some reported compounds have no guideline value.

**Scaling Factor** Not applied.

### Results

#### Organic Compound

Nitrosamines	Blank µg/L	Test µg/L	Max Allowed
!External Lab Report No.	ES2210146	ES2209659	
1-Nitrosopiperidine (NPip)	<0.003	<0.003	
1-Nitrosopyrrolidine (NPyr)	<0.01	<0.01	
Nitrosomorpholine (NMor)	<0.003	<0.003	
N-Nitrosodiethylamine (NDEA)	<0.01	<0.01	
N-Nitrosodimethylamine (NDMA)	<0.003	<0.003	0.1 µg/L
N-Nitrosodi-n-propylamine (NDPA)	<0.003	<0.003	
N-Nitrosomethylethylamine (NMEA)	<0.003	<0.003	

#### Organic Compound

Phenols	Blank µg/L	Test µg/L	Max Allowed
!External Lab Report No.	ES2210146	ES2209659	
2 4 5-trichlorophenol	<1.0	<1.0	
2 4 6-trichlorophenol	<1.0	<1.0	20 µg/L
2 4-dichlorophenol	<1.0	<1.0	200 µg/L
2 4-dimethylphenol	<1.0	<1.0	
2 6-dichlorophenol	<1.0	<1.0	
2-chlorophenol	<1.0	<1.0	300 µg/L
2-nitrophenol	<1.0	<1.0	
4-chloro-3-methylphenol	<1.0	<1.0	
m+p cresol	<2.0	<2.0	
o-cresol	<1.0	<1.0	
pentachlorophenol	<2.0	<2.0	9 µg/L
phenol	<1.0	<1.0	

#### Notes

1. Uncertainty of Measurement is reported with a coverage factor of 2 providing approximately 95% confidence interval
2. Where a result is required to meet compliance limits the associated measurement uncertainty must be considered. Measurement uncertainty is available at <https://www.awqc.com.au/our-services/Water-quality-testing-and-analysis/measurement-uncertainty>



Corporate Accreditation No.1115  
Chemical and Biological Testing  
Accredited for compliance  
with ISO/IEC 17025 - Testing





Internet: [www.awqc.com.au](http://www.awqc.com.au)

Email: [producttesting@awqc.com.au](mailto:producttesting@awqc.com.au)

**FINAL REPORT**

Report ID : 339139

**Organic Compound**

Phthalate Esters	Blank µg/L	Test µg/L	Max Allowed
!External Lab Report No.	ES2210146	ES2209659	
Bis(2-ethylhexyl) phthalate	<10	<10	10 µg/L
Butyl benzyl phthalate	<2	<2	
Di(2-ethylhexyl) adipate	<2	<2	
Diethyl phthalate	<2	<2	
Dimethyl phthalate	<2	<2	
Di-n-butyl phthalate	<2	<2	
Di-n-octyl phthalate	<2	<2	

**Organic Compound**

Polycyclic Aromatic Hydrocarbons	Blank µg/L	Test µg/L	Max Allowed
!External Lab Report No.	ES2210146	ES2209659	
Acenaphthene	<0.02	<0.02	
Acenaphthylene	<0.02	<0.02	
Anthracene	<0.02	<0.02	
Benzo(a)anthracene	<0.02	<0.02	
Benzo(a)pyrene	<0.005	<0.005	0.01 µg/L
Benzo(a)pyrene TEQ	<0.005	<0.005	
Benzo(b+j)fluoranthene	<0.02	<0.02	
Benzo(ghi)perylene	<0.02	<0.02	
Benzo(k)fluoranthene	<0.02	<0.02	
Chrysene	<0.02	<0.02	
Dibenzo(a-h)anthracene	<0.02	<0.02	
Fluoranthene	<0.02	<0.02	
Fluorene	<0.02	<0.02	
Indeno(123-cd)pyrene	<0.02	<0.02	
Naphthalene	<0.02	<0.02	
PAH - Total	<0.005	<0.005	
Phenanthrene	<0.02	<0.02	
Pyrene	<0.02	<0.02	



Corporate Accreditation No.1115  
Chemical and Biological Testing  
Accredited for compliance  
with ISO/IEC 17025 - Testing



**Notes**

1. Uncertainty of Measurement is reported with a coverage factor of 2 providing approximately 95% confidence interval
2. Where a result is required to meet compliance limits the associated measurement uncertainty must be considered. Measurement uncertainty is available at <https://www.awqc.com.au/our-services/Water-quality-testing-and-analysis/measurement-uncertainty>

**FINAL REPORT**

Report ID : 339139

**Organic Compound**

Volatile Organic Compounds GCMS	Blank µg/L	Test µg/L	Max Allowed
1 1 1 2-Tetrachloroethane	<1	<1	
1 1 1-Trichloroethane	<1	<1	
1 1 2 2-Tetrachloroethane	<1	<1	
1 1 2-Trichloroethane	<1	<1	
1 1-Dichloropropene	<1	<1	
1 2 3-Trichlorobenzene	<1	<1	
1 2 3-Trichloropropane	<1	<1	
1 2 4-Trichlorobenzene	<1	<1	
1 2 4-Trimethylbenzene	<1	<1	
1 2-Dibromo-3-chloropropane	<1	<1	1 µg/L
1 2-Dibromoethane	<1	<1	1 µg/L
1 2-Dichlorobenzene	<1	<1	1500 µg/L
1 2-Dichloroethane	<1	<1	3 µg/L
1 2-Dichloropropane	<1	<1	
1 3 5-Trimethylbenzene	<1	<1	
1 3-Dichlorobenzene	<1	<1	
1 3-Dichloropropane	<1	<1	
1 4-Dichlorobenzene	<1	<1	40 µg/L
1,1-Dichloroethane	<1	<1	
1,1-Dichloroethene	<1	<1	30 µg/L
2,2-Dichloropropane	<1	<1	
2-Chlorotoluene	<1	<1	
4-Chlorotoluene	<1	<1	
4-Isopropyltoluene	<1	<1	
Benzene	<1	<1	1 µg/L
Bromobenzene	<1	<1	
Bromochloromethane	<1	<1	
Bromodichloromethane	29	1	60 µg/L
Bromoform	5	<1	100 µg/L
Bromomethane	<4	<4	
Carbon tetrachloride	<1	<1	3 µg/L
Chlorobenzene	<1	<1	300 µg/L
Chloroethane	<4	<4	
Chloroform	26	3	400 µg/L
Chloromethane	<4	<4	
cis-1 3-Dichloropropene	<1	<1	
cis-1,2-Dichloroethene	<1	<1	
Dibromochloromethane	26	<1	150 µg/L
Dibromomethane	<1	<1	
Dichlorodifluoromethane	<1	<1	
Dichloromethane	<4	<4	4 µg/L
Ethylbenzene	<1	<1	300 µg/L
Hexachlorobutadiene	<0.7	<0.7	0.7 µg/L
Isopropylbenzene	<1	<1	
m+p-Xylenes - Total	<2	<2	



Corporate Accreditation No. 1115  
Chemical and Biological Testing  
Accredited for compliance  
with ISO/IEC 17025 - Testing



Notes

1. Uncertainty of Measurement is reported with a coverage factor of 2 providing approximately 95% confidence interval
2. Where a result is required to meet compliance limits the associated measurement uncertainty must be considered. Measurement uncertainty is available at <https://www.awqc.com.au/our-services/Water-quality-testing-and-analysis/measurement-uncertainty/>



Internet: [www.awqc.com.au](http://www.awqc.com.au)

Email: [producttesting@awqc.com.au](mailto:producttesting@awqc.com.au)

## FINAL REPORT

Report ID : 339139

### Organic Compound

Volatile Organic Compounds GCMS	Blank µg/L	Test µg/L	Max Allowed
Naphthalene	<1	<1	
n-Butylbenzene	<1	<1	
n-Propylbenzene	<1	<1	
o-Xylene	<1	<1	
sec-Butylbenzene	<1	<1	
Styrene	<1	<1	30 µg/L
tert-Butylbenzene	<1	<1	
Tetrachloroethene	<1	<1	50 µg/L
Toluene	<1	<1	800 µg/L
Total 1,2-dichloroethene	<2	<2	60 µg/L
Total 1,3-dichloropropene	<2	<2	20 µg/L
Total Trichlorobenzene	<2	<2	30 µg/L
Total Xylene	<3	<3	600 µg/L
trans-1,3-Dichloropropene	<1	<1	
trans-1,2-Dichloroethene	<1	<1	
Trichloroethene	<1	<1	
Trichlorofluoromethane	<1	<1	
Trihalomethanes - Total	86	4	250 µg/L
Vinyl chloride	<0.3	<0.3	0.3 µg/L

**Evaluation** The product passed the requirements of clause 6.8 when tested at an exposure of 2500 mm<sup>2</sup> per Litre.

**Number of Samples** 1.

**Test Comment** Not applicable.

Qiong Huang

APPROVED SIGNATORY



Corporate Accreditation No.1115  
Chemical and Biological Testing  
Accredited for compliance  
with ISO/IEC 17025 - Testing



#### Notes

1. Uncertainty of Measurement is reported with a coverage factor of 2 providing approximately 95% confidence interval
2. Where a result is required to meet compliance limits the associated measurement uncertainty must be considered. Measurement uncertainty is available at <https://www.awqc.com.au/our-services/Water-quality-testing-and-analysis/measurement-uncertainty>